

Ihre Nachricht

Unsere Zeichen
E-TFB-bosTelefon Durchwahl
88-472Telefax Durchwahl
88-92472Datum
16.02.2011

Test Report

Test report according to EN 10204-2.2

We herewith certify that the delivered product "**FFKu-EM-F-UV**" is according to the following conditions:

1. **Product:** pliable, armoured plastic conduit
Item no. 254.30. ...
2. **Supplier:** Fränkische Rohrwerke, Gebr. Kirchner GmbH & Co.KG
97486 Königsberg/Bayern
3. **Material:** special plastic
4. **Profile:** DIN EN 61386-1 / DIN EN 61386-22
DIN EN 60423
5. **Range of application:** Installation of electrical systems according to
DIN 57 100/VDE 0100
6. **Term:** FFKu-EM-F-UV 33412
7. **Classification according to DIN EN 61386** 334122400010



8. Tests

8.1	Resistance to compression:	DIN EN 61386-1	par. 6.1.1	medium	„3“
8.2	Resistance to impact:	DIN EN 61386-1	par. 6.1.2	medium	„3“
8.3	Lower temperature range:	DIN EN 61386-1	par. 6.2.1	-25°C	„4“
8.4	Upper temperature range:	DIN EN 61386-1	par. 6.2.2	+60°C	„1“
8.5	Resistance to bending:	DIN EN 61386-1	par. 6.1.3	pliable	„2“
8.6	Resistance to flame propagation :	DIN EN 61386-1	par. 6.5.1	non-flame propagating	
8.7	Dimensions:	DIN EN 60423			
8.8	Halogen-free:	not explained			
8.9	Smoke density:	not explained			

This data do not dispense the buyer from his controls on receipt and do not have the meaning of guaranteeing the suitability of the product for a concrete application. We guarantee the characteristics of our products according to contract within the scope of our General Terms of Business.

Best regards

i. A. Bodo Schmidt

This certificate is valid without being signed.

Fränkische Rohrwerke
Gebr. Kirchner GmbH & Co. KG